

Village of Kimberly 515 W. Kimberly Avenue Kimberly, WI 54136 Phone: 920.788.7507

## STORMWATER MANAGEMENT SYSTEM INSPECTION, OPERATION, & MAINTENANCE FORM

Site or Subdivision Name:			Parcel ID:		
Site Address / Location:					
Inspection Frequency (check one):					
Date of Inspection:	Inspector Name:		Maintenance Crew Leader Name:		
Maintenance Items – Bioretention or Biofiltration (1004)		Frequency	Observed?	Inspector Comments	Maintenance Completed
1. Debris & Litter – At inlets and outlets (grate, orifice, weir, pipe, filter, etc.)		R,M,B,A,C	Yes No		Yes
2. Debris & Litter – At other device locations (vegetation)		A,C	Yes No		Yes
3. Vegetation – Vegetation health or density concern (water, disease, etc.)		M,B,A,C	Yes No		Yes
4. Vegetation – Noxious weed or tree root concern (unauthorized planting, etc.)		A,C	Yes No		Yes
5. Wildlife – Burrow holes, animal paths, or other concern		A,C	Yes No		Yes
6. Erosion – Channel, rill, scour, or other erosion concern		A,C	Yes No		Yes
7. Structural inlet or outlet concern (crack, spalling, corrosion, pipe joint, etc.)		A,C	Yes No		Yes
8. Structural embankment concern (seeping, settling, slumping, roots, etc.)		A,C	Yes No		Yes
9. Structural spillway concern (dimensions, freeboard, unstable, leaking, etc.)		A,C	Yes No		Yes
10. Clogging or compaction concern (surface water > 24 hrs after > 0.5" rain)		R,M,B,A,C	Yes No		Yes
11. Clogging or compaction concern (subsurface water > 72 hrs after > 0.5" rain)		A,C	Yes No		Yes
12. Surface storage concern (depth is not within 10% of design plan, etc.)		A,C	Yes No		Yes
13. Mulch concern (mulch needed, surface storage reduced by > 10%, etc.)		A,C	Yes No		Yes
14. Filter surface concern (animal burrow holes, filter bypass, etc.)		A,C	Yes No		Yes
15. Sediment accumulation concern (surface storage depth reduced by > 10%)		С	Yes No		Yes
16. Other (graffiti, illicit discharge, illegal dumping, etc.):			Yes No		Yes

